

→ Année/Year/Año/Yıl/Rok
 → Quinzaine/Fortnight/
 Quincena/iki hafta/
 Patnáctka



Identification/Identificación/
 Identificacón/Tanımlama /
 Identifikace

Conform PED art 3.3
 Conforme DESP art 3.3

TYPE B NG REGULATOR

DESCRIPTION

The type B NG is a two-stage pressure reducing regulator with an automatic safety device to avoid outlet over-pressure (relief valve venting to atmosphere) or stopping the gas flow in the event of an abnormal drop in inlet or outlet pressure or an excess flow condition.

Rearming is manual by using the push-button and depending on models (B6 version only) a valve may be associated. A removable vent filter is situated in the inlet connection, and a vent screen (see schematic, item V).

The underground model is treated for anti-corrosion and is painted.

Maximum allowable pressure: 5 bar

Operating temperature: -20 / 60°C

Certain conditions apply for usage outside these ranges.

INSTALLATION

CAUTION

- To be used with clean, dry and non-corrosive gas.
- All regulators, except for underground version, must be protected from direct contact of water and corrosive atmosphere due to construction materials base with zinc, copper and aluminium (cabinet installation recommended).
- Recommended installation positions : inlet and/ or outlet in vertical position.
- To avoid: vent facing upwards, without protector or connector, in humid conditions (risk of water penetration due to rain or condensation).

Before connecting :

- Do not weld the inlet and outlet connections with the regulator in place.
- Remove the protective capsules from the inlet and outlet connections.
- Ensure that the pipeline is perfectly clean.
- Place the O-ring(s), (according to model) greasing is recommended.

Connection

- Respect the gas flow direction indicated on the regulator body.
- Respect the tightening torques by using a dynamometric wrench (inlet with tight shutoff metal = 40 Nm, others according to O-ring used).



WARNING

Do not re-orientate the regulator after tightening connections, under no circumstances should the regulator be put under any geometrical or dimensional consecutive force between inlet and outlet sides.

When connecting the vent (residential areas, underground) the diameter used should not be inferior to 10 mm and should not be obstructed.

COMMISSIONING OR REARMING

1

Close the downstream valve (if existent). Open the upstream valve. Press on the green button for a few seconds, then release. Open the downstream valve (if existent).

Gas Type	Density	Volum Weight kg/m ³	Pressure Setpoint Pds (mbar)	Nominal Flow	
				B6	B10
Manufactured gas (n)m ³ /h <ul style="list-style-type: none">• Butane air• Propane air	1.20	1.552	11	4	7
	1.15	1.487	11	4	7
Natural gas (n)m ³ /h <ul style="list-style-type: none">• Group L• Group H	0.64	0.827	27	6	10
	0.61	0.789	21	6	10
LP-gas kg/h <ul style="list-style-type: none">• Propane	1.56	2.017	37	7.2	12


Type B NG

 Webadmin.Regulators@emerson.com

 Fisher.com

 Facebook.com/
EmersonAutomationSolutions

 LinkedIn.com/company/emerson-
automation-solutions

 Twitter.com/emr_automation

Emerson Automation Solutions

Americas

McKinney, Texas 75070 USA

T +1 800 558 5853

+1 972 548 3574

Asia Pacific

Singapore 128461, Singapore

T +65 6770 8337

Europe

Bologna 40013, Italy

T +39 051 419 0611

Middle East and Africa

Dubai, United Arab Emirates

T +971 4 811 8100

D103697X012 © 2017 Emerson Process Management Regulator Technologies, Inc. All rights reserved. 12/17. The Emerson logo is a trademark and service mark of Emerson Electric Co. All other marks are the property of their prospective owners. Fisher™ is a mark owned by Fisher Controls International LLC, a business of Emerson Automation Solutions.

The contents of this publication are presented for information purposes only, and while effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available on request. We reserve the right to modify or improve the designs or specifications of our products at any time without notice.

Emerson Process Management Regulator Technologies, Inc does not assume responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use and maintenance of any Emerson Process Management Regulator Technologies, Inc. product remains solely with the purchaser.

Francel SAS, 3 Avenue Victor Hugo, CS 80125, Chartres 28008, France

SIRET 552 068 637 00057 APE 2651B, N° TVA : FR84552068637, RCS Chartres B 552 068 637,

SAS capital 534 400 Euro

